



Memorandum

Subject: REQUEST FOR USCG ACCEPTANCE OF 1-3/4 INCH
FIRE HOSE

16703/46-95
16703/46-34
11 July 2003

From: Commandant, United States Coast Guard (G-MSE-4)

G-MSE-4
Mr. K. Wahle
202-267-0256

To: Commander, Military Sealift Command

Ref: (a) MSC letter dated 29 May 2003, Ser N7/000599

1. Ref. (a) requests U.S. Coast Guard acceptance of 1-3/4 inch fire hose in lieu of, and in addition to, presently carried 1-1/2 inch fire hose for all USCG certificated Military Sealift Command ships.
2. As stated in ref. (a), the only effect of the substitution will be reduced friction loss when using the 1-3/4 inch hose since all couplings will be 1-1/2 inch, suitable for use with existing 1-1/2 inch hydrants, nozzles, wye gates, etc. No adapters will be required.
3. Based on the above, the request is granted.

A handwritten signature in black ink, appearing to read "J.G. Lantz".

J.G. Lantz
By direction

Copy: USCG Marine Safety Center
G-MOC